

#### Gilbert St. Complex

Is routinely monitored for constituents in the District's drinking water according to Federal and State laws. The tables show the results of the District's monitoring for the period of January 1st through December 31st, 2021.

#### Questions about this report or concerning the water system?

Contact:

Steve Samaras  
Division Manager  
(760) 955-9885 or  
(800) 554-0565

#### Office Hours:

Monday through Friday  
8:00 a.m. – 4:00 p.m.  
Closed on Holidays



**Trevor Leja**  
Assistant Director

*"We are committed to providing safe and dependable drinking water each and every day. Our team strives for exceptional water quality, reliable infrastructure, and top-notch customer service."*



**Steve Samaras**  
Division Manager

*"I would like to remind our customers to continue your conservation efforts during this ongoing drought. Your conservation efforts make a positive difference and are appreciated!"*

The Gilbert Street Complex Water System is owned by the County of San Bernardino and is operated by the Department of Public Works, Special Districts Water and Sanitation Division (Department) providing potable water services to office buildings including a juvenile detention center.

The water system consists of one well and one reservoir with a capacity of 250,000 gallons of water. The system has an auxiliary connection to the San Bernardino Municipal Water District (District) for emergencies through a CLA-VAL valve. The valve activates the District's connection when the system pressure drops below 25psi. A booster station serves the Juvenile Detention Center and consists of a pressure tank and two booster pumps.

Management and staff of the Gilbert Street Complex work as a team to ensure that the highest quality water is provided to our customers. A diligent regimen of testing and analysis for bacteriological, chemical, and radiological contaminants, along with physical qualities of the water is conducted throughout the year to ensure the highest water quality.

It is important to keep customers informed about the quality of water delivered over the past year. This year's annual Consumer Confidence Report (CCR), contains information about the contaminants detected in 2021 and previous years. The Department's responsibility is to provide a safe and dependable supply of drinking water.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the State Water Resources Control Board, (SWRCB), prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health. Additional information on bottled water is available on the California Department of Public Health website at (<https://www.cdph.ca.gov/Programs/CEH/DFDCS/Pages/FDBPrograms/FoodSafetyProgram/Water.aspx>).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at 1-800-426-4791 or visit their website at <https://www.epa.gov/dwstandardsregulations/drinking-water-contaminant-human-health-effects-information>.

This document is not a substitute for regulations, nor is it a regulation itself. Thus, it does not impose legally-binding requirements on the State Board or the Department, and may not apply to a particular situation based upon any member of the public.

This CCR reflects changes in drinking water regulatory requirements during 2021. All water systems are required to comply with the state Total Coliform Rule. Beginning April 1, 2016, all water systems are also required to comply with the federal Revised Total Coliform Rule. The new federal rule maintains the purpose to protect public health by ensuring the integrity of the drinking water distribution system and monitoring for the presence of microbials (i.e., total coliform and E.coli bacteria). The USEPA anticipates greater public health protection as the new rule requires water systems that are vulnerable to microbial contamination to identify and fix problems. Water systems that exceed a specified frequency of total coliform occurrences are required to conduct an assessment to determine if any sanitary defects exist. If found, these must be corrected by the water system.



#### ¡MUY IMPORTANTE!

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

## WATER SOURCES

**Well 1:** Ground Water; located in the Bunker Hill Sub-basin

**San Bernardino Municipal Water District connection:** an auxiliary connection

## SOURCE WATER ASSESSMENT

Source water assessments were conducted for the Gilbert Street Complex water system in 2001. Vulnerability to contamination is based on the assessment findings that include septic and sewer systems, high density housing and golf courses. A copy of the completed assessment may be viewed at the State Water Board, Division of Drinking Water located at 464 West Fourth Street, Suite 437, San Bernardino, CA 92401, or at (909) 383-4328.

## SOURCE WATER PROTECTION TIPS

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides—they contain hazardous chemicals that can leach into your drinking water source.
- Prevent septic system leaching to water sources.
- Dispose of chemicals properly; take used motor oil to a recycling center.

## The subsequent tables provide many terms and abbreviations that customers may not be familiar with. To understand these terms, the district has provided the following definitions and general information:

**1, 2, 3-trichloropropane (1,2,3-TCP)** had a notification level (NL) of 5 ppt until December 14, 2017, when the MCL of 5 ppt became effective.

**Hexavalent Chromium** there is currently no MCL for hexavalent chromium. The previous MCL of 0.010 mg/L was withdrawn on September 11, 2017.

**Inorganic contaminants**, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

**Maximum Contaminant Level (MCL)** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG)** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U. S. Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL)** The level of a disinfectant added for water treatment that may not be exceeded at the customer's tap.

**Maximum Residual Disinfectant Level Goal (MRDLG)** The level of a disinfectant added for water treatment below which there is no known or expected health risk. MRDLGs are set by the U.S. Environmental Protection Agency.

**MG** Million gallons

**Microbial contaminants**, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Million Fibers per Liter (MFL)** million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

**Millirems per year (mrem/yr)** measure of radiation absorbed by the body.

**Nephelometric Turbidity Unit (NTU)** nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

## WATER CONSERVATION TIPS

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference—try one today and soon it will become second nature.

- Take short showers—a 5 minute shower uses 10 to 25 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving to save up to 500 gallons a month.
- Use a water-efficient showerhead. They are inexpensive, easy to install, and can save you up to 740 gallons a month.
- Fix leaking toilets and faucets.
- Teach your kids about water conservation to ensure a future generation that uses water wisely.

**Non-Detect (ND)** laboratory analysis indicates that the constituent is not present or not tested.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, that are byproduct of industrial processes and petroleum production, and can also come from gas stations, urban stormwater run-off, agricultural application, and septic systems.

**Parts per billion (ppb)** one part per billion corresponds to one minute in 2,000 years.

**Parts per million (ppm)** one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per quadrillion (ppq)** one part per quadrillion corresponds to one minute in 2,000,000,000 years.

**Parts per trillion (ppt)** one part per trillion corresponds to one minute in 2,000,000 years.

**Pesticides and herbicides**, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

**Picocuries per liter (pCi/L)** Picocuries per liter is a measure of the radioactivity in water.

**Primary Drinking Water Standard (PDWS)** MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

### Public Health Goal (PHG)

The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Radioactive contaminants**, that can be naturally-occurring or be the result of oil and gas production and mining activities.

### Regulatory Action Level (AL)

The concentrations of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**UCMR4 Statement** Additional Unregulated Pollutants were added to the UCMR4 monitoring list.

**Sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water are included on the following pages:

## PRIMARY DRINKING WATER STANDARDS

County of San Bernardino – Gilbert Street Complex							
Lead and Copper (CCR Units)	Sample Date	No. of Samples Collected	90th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source
<b>Lead</b> (ppb)	2021	10	ND	0	15	0.2	Internal corrosion of household plumbing; erosion of natural deposits
<b>Copper</b> (ppm)	2021	10	0.27	0	1.3	0.3	Internal corrosion of household plumbing; erosion of natural deposits
Microbiological Contaminants							
Contaminants	Sample Period	Highest No. of Detections	No. of Months in Violation	MCL		MCLG	Typical Source of Bacteria
<b>Total Coliform</b> (State Total Coliform Rule)	2021	0	0	1 positive monthly sample		0	Naturally present in the environment
<b>Fecal Coliform or E. coli</b> (State Total Coliform Rule)	2021	0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		-	Human and animal fecal waste
<b>E. Coli</b> (Federal Revised Total Coliform Rule)	2021	0	0	(a)		0	Human and animal fecal waste
(a) Routine and repeat samples are total coliform-positive and either is <i>E. coli</i> -positive or system fails to take repeat samples following <i>E. coli</i> -positive routine sample or system fails to analyze total coliform-positive repeat sample for <i>E. coli</i> .							
Radioactive Contaminants							
Chemical or Constituent (CRR Units)	Sample Date	Average Level	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	MCL Violation	Typical Source of Contaminant
<b>Uranium</b> (pCi/L)	2021	1.4	1.4	20	0	NO	Erosion of natural deposits
Inorganic Contaminants							
Chemical or Constituent (CRR Units)	Sample Date	Average Level	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	MCL Violation	Typical Source of Contaminant
<b>Nitrate as N (NO3)</b> (ppm)	2021	6.15	6.1-6.2	10	10	NO	Runoff and leaching from fertilizer use; erosion of natural deposits
<b>Fluoride</b> (ppm)	2021	0.57	0.57	2	1	NO	Erosion of natural deposits; water additive that promotes strong teeth
<b>Hexavalent Chromium</b> (ppb)	2021	1.7	1.7	-	0.02	NO	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits
Disinfectant Byproducts and Chemical Disinfectant							
Chemical or Constituent (CRR Units)	Sample Date	Average Level	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	MCL Violation	Typical Source of Contaminant
<b>Cl Res Total</b> (ppm)	2021	0.99	0.63-1.32	4	4	NO	Drinking water disinfectant added for treatment
<b>Total Trihalomethanes – TTHM –</b> (ppb)	2021	5.75	5.7-5.8	80	N/A	NO	Byproduct of drinking water chlorination
<b>Total Haloacetic Acids – HAA5 –</b> (ppb)	2021	1.05	1–1.1	60	N/A	NO	Byproduct of drinking water disinfection



## SECONDARY DRINKING WATER STANDARDS

Chemical or Constituent (CCR Units)	Sample Date	Average Level	Range of Detections	MCL [MRDL]	PHG (MCLG)	MCL Violation	Typical Source of Contaminant
<b>Odor Threshold</b> (Units)	2021	1	1	3	N/A	NO	Naturally occurring organic materials
<b>Turbidity</b> (Units)	2021	0.43	0.35-0.5	5	N/A	NO	Soil runoff
<b>Chloride</b> (ppm)	2021	35	35	500	N/A	NO	Runoff/leaching from natural deposits; seawater influence
<b>Specific Conductance</b> (umhos/cm)	2021	670	670	1,600	N/A	NO	Substances that form ions when in water; seawater influence
<b>Total Dissolved Solids/TDS</b> (ppm)	2021	430	430	1000	N/A	NO	Runoff/leaching from natural deposits
<b>Sulfate (SO4)</b> (ppm)	2021	96	96	500	N/A	NO	Runoff/leaching from natural deposits
<b>Methyl-tert-butyl Ether (MTBE)</b> (ppb)	2021	ND	ND	5	N/A	NO	Leaking underground storage tanks; discharges from petroleum and chemical factories

## ADDITIONAL CONSTITUENTS

Chemical or Constituent	Sample Date	Average Level	Range of Detections	MCL [MRDL]	PHG (MCLG)	Typical Source of Contaminant
<b>pH (Lab)</b>	2021	7.7	7.7	N/A	N/A	N/A
<b>Aggressive Index</b>	2021	12.08	12.08	N/A	N/A	N/A
<b>Alkalinity, Total (as CaCO3)</b> (mg/L)	2021	170	170	N/A	N/A	N/A
<b>Bicarbonate (HCO3)</b> (mg/L)	2021	200	200	N/A	N/A	N/A
<b>Hardness, Total (as CaCO3)</b> (mg/L)	2021	220	220	N/A	N/A	N/A
<b>Calcium (Ca)</b> (mg/L)	2021	63	63	N/A	N/A	N/A
<b>Magnesium (Mg)</b> (mg/L)	2021	14	14	N/A	N/A	N/A
<b>Potassium (K)</b> (mg/L)	2021	3	3	N/A	N/A	N/A
<b>Sodium (Na)</b> (mg/L)	2021	61	61	N/A	N/A	N/A
<b>Carbonate (CO3)</b> (mg/L)	2021	ND	ND	N/A	N/A	N/A
<b>Total Anions</b> (meq/L)	2021	6.8	6.8	N/A	N/A	N/A

## DETECTION OF UNREGULATED CONSTITUENTS

Chemical or Constituent	Sample Date	Average Level	Range of Detections	Notification Level	Health Effects Language
<b>Boron (B)</b> (ppb)	2021	400	400	1000	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.
<b>Vanadium</b> (ppb)	2021	5.1	5.1	15	The babies of some pregnant women who drink water containing vanadium in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.



Synthetic Organic Contaminants including Pesticides and Herbicides							
Contaminant (CCR Units)	Sample Date	Average Level (PPM)	MCL (PPM)	PHG (PPB)	MCL Violation	Health Effects Language	Major Source in Drinking Water
1, 2, 3 – Trichloropropane	2020	ND	0.000005	0.0007	NO	Some people who drink water containing 1,2,3 trichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.	Discharge from industrial and agricultural chemicals factories; leaching from hazardous waste site; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.

### SHOULD CUSTOMERS BE CONCERNED?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

**Sample Dates:** The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

**Secondary Standards:** There are no PHGs, MCLGs, or mandatory standard health effect language for these constituents because secondary MCLs are set on the basis of aesthetics.

Some people who drink water containing fluoride in excess of the federal MCL of 4mg/L over many years may get bone disease, including pain and tenderness of the bones. Children who drink water containing fluoride in excess of the State MCL of 2 mg/L may get mottled teeth.

The water system failed to monitor for lead and copper during the monitoring period (June-September) 2021, however the lead and copper sampling was conducted in November 2021, the results show no Action Level exceedance for lead and copper.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Special Districts Department, Water and Sanitation Division is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Water Hotline or at <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>.

Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant’s blood to carry oxygen, resulting in serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

