



Department of Public Works
Special Districts Water and Sanitation Division
15900 Smoke Tree Street, 1st Floor
Hesperia, CA 92345
Office: (760) 955-9885

Fire Flow Test Application

PLEASE COMPLETE THIS ENTIRE SECTION:

Applicant Name:	Date:	CSA:
Mailing Address:	City:	Zip Code:
Hydrant Location:	Cross Street:	
Property Owner(s):	Property Address:	
Phone Number:	Cell Number:	Size of Parcel: acres
Assessors Parcel Number:	Total Sq. Ft. (existing & new):	including garage

Intended Use of Property: ☐ Single Family Residence Commercial Other _____

Received by: _____ Receipt Number: _____ Date Paid: _____

Pick Up Mail Email: _____ Date Sent: _____

Subsequent field investigations by the Division may determine that other charges and/or actions will be required. An itemized bill will be provided to the applicant. Property will need the address posted and the property lines staked.

****This form on its own is not a guarantee of service and must be accompanied by a valid Water and Sanitation Availability (Will-Serve) Letter issued within the last 12 months prior to a final building permit being issued****

(Office/Field Use Only)

TEST RESULTS

Fire Hydrant 1 (Flow)

Distance from Project: _____
Hydrant #: _____ Hydrant Location: _____
Type: _____ Nozzle Size: 2.5 Start Time _____
Static PSI: _____ Flow in GPM: _____ End Time _____
Pitot PSI: _____ Nozzle C Factor: 0.9

Fire Hydrant 2 (Witness Pressure)

Hydrant #: _____ Hydrant Location: _____
Type: _____ Nozzle Size: 2.5
Static PSI: _____ Residual PSI: _____

Flow calculated at 20 PSI Residual: _____ GPM

Comments: PUMPS "OFF"

Tested by: _____ Date: _____

Reviewed by: _____ Date: _____

DISTRICT ENGINEER OR DESIGNEE

Recertified by: _____ Date: _____

DISTRICT ENGINEER OR DESIGNEE

Return to Special Districts/Development Services at: devservices@sdd.sbcounty.gov

Fire Flow Test Fee: \$231.75 + 10hcf of water at the highest tier for the district.

NOTE: FIRE FLOW TESTS (FFT) ARE ONLY VALID FOR A SIX MONTH PERIOD. CONTACT DEVELOPMENT SERVICES TO RECERTIFY A FFT FOR AN ADDITIONAL SIX MONTH PERIOD.